



**LV-B1 NOTES**  
1. PANELBOARD SHALL BE DEMOLISHED AS LONG AS CIRCUITS SERVING  
OPTIONAL AREAS OF THE BUILDING REMAIN OPERATIONAL.  
2. COORDINATE WITH MECHANICAL TO ENSURE CIRCUITS 10 REMAIN  
OPTIONAL DURING DEMOLITION AND TEMPORARY MECHANICAL  
MODIFICATIONS.



**2B1 NOTES**

1. PANELBOARD SHALL BE DEMOLISHED AS LONG AS CIRCUITS SERVING OCCUPIED AREAS OF THE BUILDING REMAIN OPERATIONAL.

2. COORDINATE WITH MECHANICAL TO ENSURE CIRCUITS 10, 14, AND 16 REMAIN OPTIONAL DURING DEMOLITION AND TEMPORARY MECHANICAL MODIFICATIONS.




**LP-010 NOTES**

1. PANELBOARD SHALL BE DEMOLISHED AS LONG AS CIRCUITS SERVING OCCUPIED AREAS OF THE BUILDING REMAIN OPERATIONAL.
2. ENSURE CIRCUITS 13 REMAIN OPTIONAL DURING DEMOLITION.



**EMP-1 NOTES**  
1. ALL EMERGENCY CIRCUITS SHOULD REMAIN OPTIONAL DURING CONSTRUCTION. PROVIDE TEMPORARY POWER AS REQUIRED.



EMP-1 SCHED 2 NOTES  
1. ALL EMERGENCY CIRCUITS SHOULD REMAIN OPTIONAL DURING CONSTRUCTION.  
PROVIDE TEMPORARY POWER AS REQUIRED.